Ref. Certif. No.

CN55366

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded Case Circuit-breakers
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Ratings and principal characteristics	See the Appendix
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NM8N-400,NM8N-630,NM8NDC-400,NM8NDC-630
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2021CQC-099510

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Nov.25,2021

Signature: 谢肇煦
Xie ZhaoXu

CB 0065137

NM8N-400,NM8N-630,NM8NDC-400,NM8NDC-630
Uimp:12kV;
Ui:1000V;
Ue:AC380V/400V/415V,AC440V,AC500V,AC660V/690V,DC750V(3P in series),DC1000V(4P in series);
In: NM8N-400,NM8NDC-400:250A,315A,350A,400A(Thermo-magnetic, Electro-magnetic);
NM8N-630,NM8NDC-630:250A,315A,350A,400A,500A(Thermo-magnetic, Electro-magnetic);
250A,315A,350A,400A,500A,630A(Electronic);
Over-current release: Thermo-magnetic, Electro-magnetic, Electronic;
Ics=Icu:AC380V/400V/415V: 36kA/50kA/70kA/100kA/150kA(C/S/Q/H/R);
AC440V: 36kA/50kA/70kA/100kA/100kA(C/S/Q/H/R);
AC500V: 25kA/40kA/40kA/50kA/50kA(C/S/Q/H/R);
AC660V/690V: 10kA/12kA/12kA/15kA/15kA(C/S/Q/H/R);
DC750V(3P in series),DC1000V(4P in series): 25kA/36kA/50kA/70kA/100kA(B/C/S/Q/H);
Icw: Electronic:5kA 1s(In≤400A),8kA 1s(In≥500A);
Trip class : 5,10,20,30（ENM,EMM）;
Selectivity category: A(Thermo-magnetic, Electro-magnetic),B(Electronic);
Pole:3P,4P;
Applicable for isolation;
50/60Hz;
Auxiliary contact and alarm contact:
Type:AX21-M8,AL21-M8(CB certificate：CN46412-M1);
1NO1NC;
Ith:5A;
AC-15:Ue/Ie:AC110V/5A,AC240V/4A,AC415V/2A;
DC-13:Ue/Ie:DC110V/0.25A,DC220V/0.25A;
Accessories with electronic circuits:
Undervoltage release:
Type:UVT22-M8:
Us: AC48V, AC110V, AC220~240V, AC380~415V, 50/60Hz; DC24V,DC48V,DC110V~120V,DC220V;

Additional information (if necessary)

Date: Nov.25,2021

Signature: 谢肇煦
Xie ZhaoXu

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn

Electric operator:
Type:MOD23-M8:
Us: AC110V, AC220~240V, AC380~415V,50/60Hz; DC24V,DC110V,DC220V;
Connection diagram for DC product:











All wiring diagram are applicable to up-side wiring and/or under-side wiring,under-side wiring as a example

Additional information (if necessary)

Date: Nov.25,2021

Signature: 谢肇煦
Xie ZhaoXu

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn