Ref. Certif. No.

CN47807-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Resiual Current Operation Circuit-breaker
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Ratings and principal characteristics	See the Appendix
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NM8NL-125
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016(5th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2019CQC-085993

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Sep.23,2019

Signature: Lu Mei

CB 0053964

NM8NL-125
Uimp:8kV;
Ui:1000V;
Ue: AC380V/400V/415V,AC440V;
In: 16A,20A,25A,32A,40A,50A,63A, 80A,100A,125A;
Over-current release: Thermo-magnetic, Electro-magnetic;
Ics=Icu:
AC380/400/415V:36kA/50kA/70kA/100kA/150kA(C/S/Q/H/R);
AC440V:36kA/50kA/70kA/100kA/100kA(C/S/Q/H/R);
Rated residual operating current I△n:
RCD1:0.03A/0.1A/0.3A/1A adjustable(0.03A is non-delay type, other tap positions are Time-delay/Non-time-delay)
RCD2:0.05A/0.2A/0.5A/2A adjustable(Time-delay/Non-time-delay)
Residual current Release Type: Electronic/Type A, Type AC;
Rated residual short-circuit making and breaking capacity I△m:25%Icu;
Selectivity category: A;
3P,4P;
Applicable for isolation;
50/60Hz;
Auxiliary contact and alarm contact:
Type:AX21-M8,AL21-M8(CB certificate:CN46412-M1);
1NO1NC;
Ith:5A;
Ue/Ie:
AC-15: AC110V/5A,AC240V/4A,AC415V/2A;
DC-13: DC110V/ 0.25A,DC220V/0.25A;
Accessories with electronic circuits:
Undervoltage release:
Type:UVT21-M8:
Us: AC48V, AC110V, AC220-240V, AC380-415V 50/60Hz,
DC24V,DC48V,DC110V-120V,DC220V;

Additional information (if necessary)

Date: Sep.23,2019

Signature: Lu Mei

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn

Electric operator:
Type:MOD21-M8:
Us: AC110V, AC220-240V, AC380-415V 50/60Hz,DC24V,DC110V,DC220V

Additional information (if necessary)

Date: Sep.23,2019

Signature: Lu Mei

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn